

ADDENDUM #2

TO

CONTRACT DOCUMENTS

Hudson Dog Park

HUDSON, MASSACHUSETTS

June 05, 2025

NOTICE TO BIDDERS

The attention of all bidders submitting proposals for “**Hudson Dog Park**” is called to the following Addenda to the printed specifications and plans. The items set forth herein, whether of omission, addition or substitution are to be included in, and form part of the specifications and plans of the above named project for bids to be received as advertised.

The following clarifications, modifications, deletions, and additions are hereby incorporated into and become part of the Contract Documents.

Receipt of this Addendum shall be noted on the Form for Bid

Bids must be submitted before **12:00 P.M., Boston time, Monday, June 9, 2025**. There is no change in this bid submission time.

QUESTIONS WITH RESPONSES:

1.0 Clarifications to the chain link fence

- Dog Park Fence:
 - The chain link fence around the dog park shall be 5' in height.
 - Gates shall be 5' in height.
 - Line posts shall be 2-1/2" vinyl-coated steel pipe
 - Max post spacing shall be 10' o.c., unless otherwise shown on the construction drawings.
 - The fence fabric shall be 9 gauge vinyl-coated steel fabric, with 2" mesh openings.
 - The top and bottom rails shall be 1-5/8" o.d. vinyl-coated steel pipe.
 - No middle rail is required.
 - Terminal posts do not require diagonal truss rods.
- Trash enclosure:
 - Chain link fence shall be 6' in height.
 - Gates shall be 6' in height.
 - Line posts shall be 2-1/2" vinyl-coated steel pipe
 - Top and bottom rails shall be 1-5/8" o.d. vinyl-coated steel pipe.
 - The fence fabric shall be 9 gauge vinyl-coated steel fabric, with 2" mesh

- openings and black privacy slats.
- Gate frame shall be constructed of 2" vinyl-coated steel pipe.